

New Port Road

Ellesmere Port, CH65 4LZ **United Kingdom** 

# **IECEx Certificate** of Conformity

# INTERNATIONAL ELECTROTECHNICAL COMMISSION

IEC Certification System for Explosive Atmospheres

for rules and details of the IECEx Scheme visit www.iecex.com

Certificate No .:	IECEx CML 19.0095X	Page 1 of	4	Certificate history:
Status:	Current	Issue No:	2	Issue 1 (2020-11-20) Issue 0 (2019-10-31)
Date of Issue:	2023-05-23			
Applicant:	HMi Elements Limited Unit A & B, Windmill Industrial Estate Showfield Lane, Malton North Yorkshire YO17 6BT United Kingdom			
Equipment:	1801-Z1 Data Acquisition Unit			
Optional accessory	:			
Type of Protection:	Flameproof "db", Increased Safety "et	o", Intrinsic Safety "ib", Encapsula	tion "mb"	
Marking:	Ex db eb ib mb IIC T4 Gb			
	Ta = -40°C to +60°C			
Approved for issue Certification Body:	on behalf of the IECEx	A Snowdon		
Position:		Certification Manager		
Signature:		A Showdon		
(for printed version)		1 1 JUGHIADA		
Date: (for printed version)		2023-05-23		
2. This certificate is n	schedule may only be reproduced in full. ot transferable and remains the property of the issuin henticity of this certificate may be verified by visiting v			
Certificate issue	d by:			
Eurofins E&E	CML Limited			<b>c</b>
Unit 1, Newpor	t Business Park		🛟 euro	tins (cml



#### **TEST & ASSESSMENT REPORTS:**

A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in:

Test Reports:

GB/CML/ExTR19.0119/00

GB/CML/ExTR20.0230/00

GB/CML/ExTR23.0100/00

Quality Assessment Report:

NO/DNV/QAR09.0001/09



# IECEx Certificate of Conformity

Certificate No.: IECEx

IECEx CML 19.0095X

Date of issue:

Page 3 of 4

Issue No: 2

#### EQUIPMENT:

Equipment and systems covered by this Certificate are as follows:

2023-05-23

The 1801-Z1 Data Acquisition Unit is an industrial stand alone data acquisition terminal for use in hazardous areas requiring equipment protection level Gb.

The equipment comprises a metallic IP66 rated enclosure with a sealed membrane front panel with OLED display and keypad. An internal flameproof compartment houses the power supply, computer unit, and multiple boards and interfaces. The display and keypad are intrinsically safe and are connected to circuits within the flameproof compartment via intrinsically safe barrier circuits.

Refer to Annex for full description and conditions of manufacture.

SPECIFIC CONDITIONS OF USE: YES as shown below:

Refer to Annex for specific conditions of use.



# IECEx Certificate of Conformity

Certificate No.:

IECEx CML 19.0095X

Date of issue:

2023-05-23

Page 4 of 4

Issue No: 2

# DETAILS OF CERTIFICATE CHANGES (for issues 1 and above) Issue 1

This issue introduced the following changes:

- 1. Changes to circuits and PCB layouts
- 2. The use of alternative wire types

#### Issue 2

This issue introduced the following changes:

- 1. The introduction of new intrinsically safe I/O interfaces
- 2. The introduction of a heater mat
- 3. The introduction of an alternative dump valve power supply
- 4. The introduction of flexible build options

#### Annex:

Certificate Annex IECEx CML 19.0095X Iss 2.pdf





Annexe to:	IECEx CML 19.0095X, Issue 2
Applicant:	HMi Elements Ltd.
Apparatus:	1801-Z1 Data Acquisition Unit

CML

### **Description**

The 1801-Z1 Data Acquisition Unit is an industrial standalone data acquisition terminal for use in hazardous areas requiring equipment protection level Gb.

The equipment comprises a metallic IP66 rated enclosure with a sealed membrane front panel with OLED display and keypad. An internal flameproof compartment houses the power supply, computer unit, and multiple boards and interfaces. The display and keypad are intrinsically safe and are connected to circuits within the flameproof compartment via intrinsically safe barrier circuits.

Multiple wired and wireless outputs are provided for the connection of external equipment, including intrinsically safe connections which are connected to circuits within the flameproof compartment via intrinsically safe barrier circuits.

The equipment may be fitted with any number of intrinsically safe connectors, as detailed in the user instructions. The intrinsically safe connections may be any of the following types:

Circuit type	Description	Output parameters		
Rotary	One power and two		is coi	mbined w.r.t. 0V
Encoder	signal outputs.	Uo	=	5.88V
SA1236		lo	=	194mA
		Po	=	0.283W
		Ci	=	0
		Li	=	0
Load cell	6 off outputs	Between any two outputs		
SA1239 or		Uo	=	5.88V
SA1916		lo	=	59mA
		Po	=	0.09W
		Ci	=	0
		Li	=	0
Servo	2 off AC outputs	For each AC output (between pins)		
SA1240		Uo	=	15.42V
		lo	=	24mA
		Po	=	0.091W
		Ci	=	0
		Li	=	0

Eurofins E&E CML Limited Newport Business Park New Port Road Ellesmere Port CH65 4LZ

T +44 (0) 151 559 1160 E info@cmlex.com

www.cmlex.com



Certificate Annex IECEx Version: 9.0 Approval: Approved



0	Description			
Circuit type	Description	Output parameters		
Dual horn	Two 24V switched outputs		ach o	output (w.r.t. 0V)
SA1235	ouipuis	Uo	=	26.0V
		lo	=	88mA
		Po	=	0.57W
		Ci	=	0
		Li	=	0
Digital	3 off switch inputs For each input (between pins)		nput (between pins)	
buttons		Uo	=	9.14V
SA1242		lo	=	9.1mA
		Po	=	0.021W
		Ci	=	0
		Li	=	0
4-20mA loop 2 off 4-20mA loop For each loop				
and switches	connections	Uo	=	
SA1238		lo	=	65mA
		Po		0.48W
		Ci		0
		Li		0
	2 off switch inputs	For each switch		
		Uo	=	29.4V
		lo	=	33mA
		Po	=	0.24W
		Ci	=	0
		Li	=	0
NAMUR and	3 off NAMUR	For each input (between pins)		
Encoder	compatible switch	Uo	=	
SA1806	inputs	lo	=	9.1mA
		Po	=	0.021W
		Ci	=	0
		Li	=	0
	One power and two	All pins combined w.r.t. 0V		
	signal outputs.	Uo	=	5.88V
		lo	=	195mA
		Po	=	0.285W
		Ci	=	0
		Li	=	0



Circuit type	Description	Output parameters	
4-20mA loop SA1909	2 off 4-20mA loop connections	For each loop Uo = 27.3V Io = 61mA Po = 0.41W Ci = 0 Li = 0	
WIFI	N/A	Capacitively coupled	
Antenna	N/A	Capacitively coupled	

The following electrical connections to the equipment are not intrinsically safe and are made via cable glands or separately certified connectors:

Connector/entry	Rating		
AC supply in	100Vac – 240Vac 50/60Hz, 1.0A		
AC supply out	100Vac – 240Vac 50/60Hz, 1.0A		
LAN	100Vac – 240Vac 50/60Hz, 1.0A		
Dump	100Vac – 240Vac 50/60Hz, 1.0A		

### **Conditions of Manufacture**

The following conditions are required of the manufacturing process for compliance with the certification.

- i. Where the product incorporates certified parts or safety critical components, the manufacturer of the product defined on this certificate shall continually monitor these parts/components for any modifications introduced by the manufacturer(s) of these constituent parts. If the manufacturer of any constituent part introduces any changes which affect the compliance of the certified product that is the subject of this certificate, the manufacturer is required to have this certificate updated.
- ii. The flameproof enclosure, complete with blanking plugs, shall be subjected to an overpressure test at a minimum pressure of 25 bar in accordance with IEC 60079-1:2014 clause 16. There shall be no damage or permanent deformation of the enclosure nor shall there be any leakage through the enclosure walls. The lid and base of the flameproof enclosure may be tested separately.
- iii. Each fuse assembly shall be visually inspected. No damage shall be evident, such as cracks in the compound, exposure of encapsulated parts, flaking, inadmissible shrinkage, swelling, decomposition, failure of adhesion, or softening.



- iv. Each fuse assembly shall be subjected to an electric strength test in accordance with IEC 60079-18 Clause 9.2 using a test voltage of 1500Vac applied between the terminals and the surface of the encapsulant (covered in foil), for a period of 1 second. Alternatively:
  - a) a voltage of 20% higher may be applied for 0.1 second
  - b) a d.c. test voltage is allowed as an alternative to the a.c. test voltage and shall be 170% of the specified a.c. r.m.s. test voltage.

Alternatively, the equipment may be subjected to batch testing in accordance with IEC 60079-18 Ed.4.1 Annex C.

- v. The equipment shall be subjected to an electric strength test in accordance with the requirements of IEC 60079-7 Clause 6.1 using a test voltage of 1500Vac applied between the supply terminals and frame, for a period of 1 second.
  Alternatively, a d.c. test voltage is allowed as an alternative to the a.c. test voltage and shall be 170% of the specified a.c. r.m.s. test voltage.
- vi. The manufacturer shall ensure that any equipment certified cable glands, bushings, breather drains, and connectors fitted to the equipment meet the requirements of IEC 60079-0 Ed. 7, IEC 60079-1 Ed. 7, and IEC 60079-7 Ed. 5 as appropriate, and that all conditions of use and relevant ratings are adhered to. All such parts shall be suitable for use at a service temperature range -40°C to 70°C. Any such parts fitted to the exterior of the equipment enclosure shall provide a minimum ingress protection of IP66.
- vii. Entries into the equipment for all non intrinsically safe connections shall be via suitably certified cable glands or via suitably certified Ex d e plugs and sockets.
- viii. The manufacturer shall ensure that the customer specific instructions provide details of the circuits and applicable intrinsically safe parameters for each of the intrinsically safe connections.

### **Specific Conditions of Use**

The following conditions relate to safe installation and/or use of the equipment.

- i. Under certain extreme circumstances, the non-metallic parts incorporated in the enclosure of this equipment may generate an ignition-capable level of electrostatic charge. Therefore, the equipment shall not be installed in a location where the external conditions are conducive to the build-up of electrostatic charge on such surfaces e.g. where a charge-generating mechanism (such as wind-blown dust) is possible. In addition, the equipment shall only be cleaned with a damp cloth.
- ii. The bolts securing the lid of the flameproof compartment shall be M6 x 24 mm (min) to 36 mm (max) alloy steel hexagon socket head types with a material grade of 12.9 or better.
- iii. The user shall refer to the user specific instructions for details of the intrinsically safe parameters applicable to their equipment.



## Components covered by Ex Certificates issued to older editions of Standards

Certificate number	Standards (incl Ed)	Assessment result
IECEx KEM 10.0093U	IEC 60079-0 Ed. 6	Technical differences
	IEC 60079-7 Ed. 4	evaluated and found satisfactory. For detail see
IECEx SEV 14.0010U	IEC 60079-0 Ed. 6	ExTR
	IEC 60079-7 Ed. 4	
IECEx UL 13.0077U	IEC 60079-0 Ed.6	